

7/19/2017 Hearing notes DEP #93-365

NOI for 420 Main St, Neil Gorman from Ross Associates septic replacement

Hearing opened at 8:30 for 420 Main Street septic replacement for SFH.

Neil submitted new page 1 with corrected applicant address and an updated plan revised today for erosion control changes (to silt fence with straw bale from wattles) as discussed at the site visit.

Existing system is cesspool approx. 50' from the wetland. Will tie in to existing plumbing, pumped uphill to a leaching system 78' from the wetlands. Existing system will be emptied, crushed and backfilled.

New system is a Presby to reduce footprint. The majority of the property is within the 100' buffer. Seeking variances from BOH.

Stabilizing slope with loam and seed. Neil feels that will be sufficient. We will make a condition if not a growing season then jute matting will be required since the graded slope is within 25' of the wetlands in some places.

Vote to issue Orders 3-0 in favor. Cathy will do the OOC. They will pick up 8/2.