

Date: September 16, 2014
(Revised: December 19, 2014)

**DRAFT PROGRESS REPORT
ENERGY STUDY
for the
Ashby Police Department**



**Energy Analysis of Measures
Through the
Massachusetts Clean Energy Center
Green Communities Program**

Completed By:

**Bales Energy Associates
50 Miles Street
Greenfield, MA 01301
bart.bales@balesenergy.com
413-863-5020**

Table of Contents

Introduction	3
Executive Summary	3
Energy Conservation Opportunities Evaluated	3
Executive Summary Chart	5
Fuel Energy Reduction Chart	6
Existing Conditions	6
Facility Description	6
Utility Energy Use	6
Building Enclosure	6
Recommendation: Building Enclosure Improvements	7
Heating, Ventilation & Air Conditioning Systems	7
Furnace	7
Recommendation: Heating System Improvement Options	8
Heating & Cooling Distribution System	8
Cooling System	8
Temperature & Ventilating Control System	8
Domestic Hot Water System	8
APPENDICES	9
UTILITY INFORMATION	10
ENCLOSURE MEASURE INFORMATION	12
ZONING & CONTROL MEASURE	14
HEATING SYSTEM MEASURE	15
BASELINE HEAT BALANCE CALCULATIONS	18
Enclosure ECM 1.1 Heat Balance	21
Enclosure ECM 1.2 Heat Balance	23
Zoning & Control ECM 2.1 Heat Balance	25
GREENHOUSE GAS EMISSIONS	27

Introduction

Bales Energy Associates (BEA), an energy efficiency engineering firm, was contracted to provide an energy study for selected town-owned buildings in Ashby, Massachusetts. The study was funded through grant funds provided by Green Communities Program of the Massachusetts Clean Energy Center. The building evaluated in this report is the Police Station, located at 893 Main Street.

Bart Bales, PE, MSME, senior engineer at BEA, visited the site, reviewed energy usage & billing information, examined relevant equipment and systems, and developed energy analyses and recommendations with regard to each building's energy related systems.

Given the nature of the funding process for the Green Communities Program, a preliminary site visit identified specific measures for inclusion in the current report. Other potential measures identified in the course of this study have been noted and may be considered for evaluation for future Green Communities grant applications.

Note: Through the course of this study, BEA has evaluated specific system improvement opportunities including building enclosure, HVAC, controls, domestic hot water and other mechanical and electrical systems. This analysis was completed to a level sufficient for recommending and calculating potential energy and dollar savings and for estimating costs for recommended energy system improvements to aid the client in making an informed decision on implementation of the recommendations provided.

Disclaimer: An added design phase for development of final design documents for construction implementation is assumed and recommended to follow this report. This study may be used as a starting point with supporting information for development of final system design and specification documents.

Verification of all field measurements and recalculation of all heat load and final system sizing calculations are the responsibility of the final designer of record. Design implementation may be accomplished by either of the following methods: plan-specification-bid process or performance specification-design-build process.

Executive Summary

Energy Conservation Opportunities Evaluated

During the proposal and contracting process, specific energy conservation measures needing evaluation were identified at each facility. ASHRAE Level II calculations were completed for all measures evaluated.

Building envelope improvements, both adding insulation and air sealing, and space conditioning temperature controls were the focus of the study at the Ashby Police Department.

Key conclusions are the following:

1. **Enclosure Improvement Options:** These can substantially reduce the building's heat loss characteristics. Recommendations include:

- **ECM 1.1 - Insulate the floor above the crawl space levels.** Add sufficient insulation to increase the floor assembly R-value to R24. Air seal bypasses and penetrations in the floor.

OR

- **ECM 1.2 - Construct a sealed and insulated crawl space below the building.** Remove the existing plywood that wraps the base of the building and replace it with an insulated 'wall'. Also apply layer of plastic over the ground surface and completely seal at the seams and edges.

2. HVAC System Recommendation Options:

- **ECM 2.1 - Separate the building into two zones.** Install a secondary air damper and a microprocessor-based programmable thermostat to allow for separate temperature control and setback for locker room side of the station.

OR

- **ECM 2.2 - Install an air source heat pump system (ASHP).** Replace the existing oil-fired furnace with and super efficient mini-split style ASHP to both heat and cool the building.

Though outside the scope of the building related services contracted and addressed in this report, BEA recognizes that idling of police vehicles represents a significant energy use. BEA recommends implementation of a policy to minimize vehicle idling to realize the potential savings.

The costs, savings, and economic payback for these energy conservation measures are presented in the following Executive Summary Chart. The values shown represent the savings with measures taken in the order of economic feasibility shown. The calculations supporting each measure are included in the appendices.

Executive Summary Chart

Natural Gas		Propane	Oil	Electricity
per therm		per gal	per gal	per kWh
		\$3.24	\$3.24	\$0.17

Executive Summary Chart							
Green Communities Study							
Measure #	Measure Description <i>(RM = Renewable Thermal Measure)</i> <i>(ECM = Energy Conservation Measure)</i>	Fuel Energy Savings (% of base)	Annual Savings (\$ / yr)	Available Incentive (\$)		Incremental Cost Difference *	
				Full Cost	After Incentive	Full Cost	After Incentive
				Cost (\$)	Payback (yrs)	Cost (\$)	Payback (yrs)
ECM 1.1	Insulate & Air Seal the Floor	51%	\$ 1,348	\$ 13,883	10.3	\$ 13,883	10.3
OR							
ECM 1.2	Construct Insulated & Sealed Crawlspace	47%	\$ 1,261	\$ 12,966	10.3	\$ 12,966	10.3
ECM 2.1	Energy Management System Controls	10%	\$ 273	\$ 1,750	6.4	\$ 1,750	6.4
OR							
ECM 2.2	Heating with Air Source Heat Pump (ASHP)	40%	\$ 1,174	\$ 24,452	20.8	\$ 24,452	20.8

*Incremental = (Full Cost) - (Replacement-In-Kind of Existing)

Fuel Energy Reduction Chart

		Fuel Energy Impact						
		Natural Gas	Propane	Oil	Electricity			
		100.0 kBtu / therm	92.5 kBtu / gal	138.7 kBtu / gal	3.413 kBtu / kWh			
Baseline Energy Use		Natural Gas	Propane	Oil	Electricity	Fuel Energy		
Space Heating & Domestic Hot Water				823		114,095		
Measure #	Measure Description <i>(RTM = Renewable Thermal Measure)</i> <i>(ECM = Energy Conservation Measure)</i>	Fuel Usage After Measures				Fuel Energy Use (kBtu / yr)	Fuel Energy Savings (kBtu / yr)	Savings As % of Baseline
		Natural Gas (gal / yr)	Propane (gal / yr)	Oil (gal / yr)	Electricity (kWh / yr)			
ECM 1.1	Insulate & Air Seal the Floor			407		56,465	57,629	51%
OR								
ECM 1.2	Construct Insulated & Sealed Crawlspace			434		60,189	53,906	47%
ECM 2.1	Energy Management System Controls			323		44,790	11,676	10%
OR								
ECM 2.2	Heating with Air Source Heat Pump (ASHP)				3,247	11,080	45,385	40%

Existing Conditions

Facility Description

This facility is an old single-wide modular-style building. It is understood that the department was moved into this space after it was vacated by the elementary school when it was used by them during a school renovation project. The department uses it 7 days a week and it's occupied by at least one person 24 hours per day. The structure is not efficient from either an energy or department needs perspective.

Utility Energy Use

Utility data for a multi-year period was collected and reviewed. Data for the (May 2013 - April 2014) reference year used for heat balance purposes is tabulated and reported in the appendices. For that period, the annual electrical usage was 45,620 kWh; the annual oil consumption was 822 gallons. Energy usage expressed in common energy units resulted in an annual total of 269,750 kBtu per year. Per heated square foot of floor area, energy usage was a relatively high value of 152.8 kBtu/ft².

Building Enclosure

The building has an asphalt shingle roof over an SIP type panel roofing system of approximately 6" thickness forming a vaulted/cathedral ceiling inside. The exterior walls are wood frame 2" x 4" structure and are assumed to have fiberglass batt insulation in the stud cavity though the assigned r-value used in the heat balance calculations are reduced to only R-6 to account for poor condition being assumed. The floor is perhaps the largest contributor to the poor envelope conditions in the space. The combined r-value assigned to this building component is R-3.6. Windows are single pane glass, sliding units all on the front wall facing southwest.

Recommendation: Building Enclosure Improvements

Bales Energy Associates recommends reducing heat loss through the floor of the building. This could be accomplished by either of the following approaches: *(Note: In both methods, any plumbing and mechanicals exposed to the air would be sealed and insulated appropriately to limit exposure to freezing and heat loss.)*

- **ECM 1.1 - Insulate the floor above the crawl space level.** Add sufficient insulation to increase the floor assembly R-value to R24. Air seal bypasses and penetrations in the floor. This measure was calculated using open cell spray-applied foam insulation to the floor assembly between the occupied area and the crawl space.

OR

- **ECM 1.2 - Construct a sealed and insulated crawl space below the building.** This would require removing the existing plywood and frame structure that currently serves to minimize animal activity under the structure and provides a slight barrier that limits air and temperature impact on the floor and existing piping and mechanicals below. A new frame would be constructed to secure 4" of foam board insulation to and would hold an exterior layer over the insulation to protect it. In addition, a layer of plastic sheeting would be applied to the entire ground surface inside this perimeter to serve as a moisture/vapor barrier. This plastic would have taped seams, be folded up at the edges and taped to the wall.

System costs and energy and dollar savings are reported in the appendices of this report.

Heating, Ventilation & Air Conditioning Systems**Furnace**

The furnace used to heat the space is a Rheem Imperial oil-fired furnace with an input of 105 MBH at 0.75 GPH burner input. The gross output is therefore 104,025 Btu/hr.

The modeled design heat load for the building as currently configured and designed is approximately 66,000 Btu/hr.

After the completion of the recommended Energy Conservation Measures (ECM), the design heat load of the building was calculated to be 51,000 Btu/hr. Sizing of the heating system in this report assumes the lower design heat load required after implementation of the recommended enclosure improvement measures. All estimates and quotes were based on this value.

Note: Any future quotations and heat load calculations should take into account any design heat load reductions due to implementation of the measures recommended in this report.

Recommendation: Heating System Improvement Options

- **ECM 2.1 - Separate the building into two zones.** If retaining the existing furnace system to heat the building, install a secondary air damper and a microprocessor-based programmable thermostat to allow for separate temperature control and setback for locker room side of the station.

OR

- **ECM 2.2 - Install an air source heat pump system (ASHP).** Replace the existing oil-fired furnace with and super efficient mini-split style ASHP to both heat and cool the building. This option also evaluated separating the building into two zones and included the installation of two (2) outdoor compressor units and two (2) wall-mounted indoor units (one paired set for each zone). These units would be sized to supply 100% of the design heat load to the building.

Heating & Cooling Distribution System

The heating distribution system consists of supply and return ducting to/from the conditioned space. All supply ductwork, which comes off the downdraft furnace from below it, is located beneath the floor. Though a visual inspection of the ducting was not possible on the day of the walk through, it is quite possibly outside the thermal envelope and, if so, loses heat to the outside and very inefficient. It is also reasonable to assume that if/when the supply ducting was insulated it is much less effective at this stage of its life than when first installed. The return ductwork is located in the ceiling cavity above the bathrooms and closet space in the center of the building.

Cooling System

The station is air conditioned by three window air conditioning units permanently installed in a through-the-wall configuration. There are two located in the office side of the building and one on the other.

Temperature & Ventilating Control System

There is one thermostat installed on the office side of the police station. This operates the furnace for the whole building.

Domestic Hot Water System

A 12 gallon electric hot water tank serves the DHW demand at the Police Department.

APPENDICES

UTILITY INFORMATION

MAY 2013 - APR 2014								
Billed Energy Use Table for Electricity & Fuel								
Building Name	Police Station							
Owner	Town of Ashby							
Account #								
Month	Electricity KWH	Billed Demand KW	Delivery Charged \$	Supplier Charged \$	Electricity Total \$	Oil Gallons	Oil \$	Energy \$ Totals
May 2013	3536	9.0	\$357	\$226	\$582			\$582
Jun	4560	10.5	\$426	\$321	\$748			\$748
Jul	5640	11.5	\$502	\$428	\$929			\$929
Aug	5142	11.0	\$464	\$392	\$855			\$855
Sept	4534	11.0	\$409	\$318	\$727			\$727
Oct	3444	9.5	\$322	\$233	\$555			\$555
Nov	3284	6.5	\$280	\$232	\$512	89.2	\$284	\$795
Dec	3056	7.5	\$277	\$281	\$558	148.6	\$478	\$1,036
Jan 2014	3233	7.5	\$293	\$362	\$654	196.9	\$649	\$1,304
Feb	3349	7.0	\$296	\$258	\$555	176.3	\$596	\$1,150
Mar	2993	6.5	\$268	\$258	\$527	211.6	\$662	\$1,189
Apr 2014	2849	7.0	\$264	\$206	\$470			\$470
Annual (Units)	45,620		\$4,158	\$3,513	\$7,672	822.6	\$2,669	\$10,340
Heating Season (Units)	22,208		\$2,001	\$1,829	\$3,830	822.6	\$2,669	\$6,499
Annual (\$/Unit)			\$0.09	\$0.08	\$0.17		\$3.24	
Heating Season (\$/Unit)			\$0.09	\$0.08	\$0.17		\$3.24	
	Electricity MBtu					Oil MBtu	Energy Use Totals (Mbtu)	
Annual (Mbtu)	155,655					114,095	269,750	Energy \$ Totals
Heating Season (Mbtu)	75,774					114,095	189,868	
						Totals (Mbtu/sf)	(\$/sf)	
Annual (Mbtu/sf)	88.2					64.6	152.8	\$5.86
Heating Season (Mbtu/sf)	42.9					64.6	107.6	\$3.68
Building Name	Police Station					Heated Square Footage	1,765	

ENCLOSURE MEASURE INFORMATION

Summary of Energy Savings											
ECM 1.1 Insulate & Air Seal the Floor											
	Baseline	After ECM 1.1	Savings	Reduction							
Net Building Demand (MMBtu/yr)	76.2	37.7	38.48	50.5%							
Existing Seasonal System Efficiency	67%	67%									
Fuel Energy Usage (MMBtu/yr)	114.1	56.5									
Energy Savings	% Reduction	Oil Use	Gallons Saved	\$/Unit	\$ Saved						
	50.5%	823	415	\$3.24	\$1,348						
Total Savings					\$1,348						
<table border="1"> <thead> <tr> <th>Cost</th> <th>Savings</th> <th>Payback (yr)</th> </tr> </thead> <tbody> <tr> <td>\$13,883</td> <td>\$1,348</td> <td>10.3</td> </tr> </tbody> </table>						Cost	Savings	Payback (yr)	\$13,883	\$1,348	10.3
Cost	Savings	Payback (yr)									
\$13,883	\$1,348	10.3									
<i>Note:</i>											

Entire Facility Floor		1,765 sq.ft.
0		0.0 "
	Depth (in.)	R-value
Open Cell Spray Foam	7	25
	-	-
	Cost (\$)	
		\$ 11,474
	Subtotal	\$ 11,474
	Contingency	\$ 1,147
	Totals	\$ 12,621
Advisory & Contractor Oversight		\$ 1,262
	Totals	\$ 13,883

Summary of Energy Savings											
ECM 1.2 Construct Insulated & Sealed Crawlspace											
	Baseline	After ECM 1.2	Savings	Reduction							
Net Building Demand (MMBtu/yr)	76.2	40.2	36.00	47.2%							
Existing Seasonal System Efficiency	67%	67%									
Fuel Energy Usage (MMBtu/yr)	114.1	60.2									
Energy Savings	% Reduction	Oil Use	Gallons Saved	\$/Unit	\$ Saved						
	47.2%	823	389	\$3.24	\$1,261						
Total Savings					\$1,261						
<table border="1"> <thead> <tr> <th>Cost</th> <th>Savings</th> <th>Payback (yr)</th> </tr> </thead> <tbody> <tr> <td>\$12,966</td> <td>\$1,261</td> <td>10.3</td> </tr> </tbody> </table>						Cost	Savings	Payback (yr)	\$12,966	\$1,261	10.3
Cost	Savings	Payback (yr)									
\$12,966	\$1,261	10.3									
<i>Note:</i>											

Approx. Area of Perimeter Skirt 'Wall'	390 sq.ft.
Two Layers of 2" Rigid Foam (2' x 8')	4.0 "
	Depth (in.) R-value Cost (\$)
Material for Perimeter Skirt 'Wall'	4 28 \$ 1,976
Labor for Perimeter Skirt 'Wall'	- - \$ 6,080
Material for Plastic Ground Cover	- - \$ 380
Labor to Install Plastic Sheeting	- - \$ 2,280
Subtotal	\$ 10,716
Contingency	\$ 1,072
Totals	\$ 11,787
Advisory & Contractor Oversight	\$ 1,179
Totals	\$ 12,966

ZONING & CONTROL MEASURE

Summary of Energy Savings											
ECM 2.1 Energy Management System Controls											
	Baseline (after ECM 1.1)	After ECM 2.1	Savings	Reduction							
Net Building Demand (MMBtu/yr)	37.7	29.9	7.80	20.7%							
Marginal System Efficiency	72%	72%									
Fuel Energy Usage (MMBtu/yr)	52.4	41.5									
Energy Savings	% Reduction	Projected Oil Use	Gallons Saved	\$/Unit	\$ Saved						
	20.7%	407	84	\$3.24	\$273						
		(after enclosure ECM)									
Total Savings					\$273						
<table border="1"> <thead> <tr> <th>Cost</th> <th>Savings</th> <th>Payback (yr)</th> </tr> </thead> <tbody> <tr> <td>\$1,750</td> <td>\$273</td> <td>6.4</td> </tr> </tbody> </table>						Cost	Savings	Payback (yr)	\$1,750	\$273	6.4
Cost	Savings	Payback (yr)									
\$1,750	\$273	6.4									
<i>Note:</i>											

Zoning & Zone Control Improvement Costs	
	Cost (\$)
Install New Zone Damper in Supply Ductwork of Furnace	\$ 1,250
Install New Thermostat(s)	\$ 500
Contingency	
Totals	\$ 1,750
Advisory & Contractor Oversight	
Measure Total	\$ 1,750

HEATING SYSTEM MEASURE

ECM 2.2		Heating with Air Source Heat Pump (ASHP)			
		Police Station			
Fuel Rate (\$/gallon)				Electric Rate (\$/kWh)	
\$3.24	Existing Condition:		New Condition:	\$0.17	
	Furnace		ASHP		
Heating Unit #	1		1	2	
Make	Rheem		Mitsubishi	Mitsubishi	
Model			PUZ-HA36NHA4	MUZ-FE18NA	
Type	Atmospheric		VRF	VRF	
Heating Medium	Air		Air	Air	
Control Mode			Variable	Variable	
Output kBtu/Hr	85	kBtu/Hr	38	18	
Steady State Eff	81%	Max. @ 5 degree O.A.T.			
Input kBtu/Hr	105	W / hr	6,318	2,978	
Seasonal Eff	67%		270%	270%	
Percentage of Load	168%		75%	35%	
Replacement-In-Kind Costs		Installed System Costs			
Furnace	\$0	Mitsubishi ASHP Outdoor Unit(s) & Mitsubishi ASHP Indoor Unit(s)	\$13,968		
		Installation & Electrical	\$6,240		
			\$20,208	Subtotal	
		Contingency	\$2,021		
			\$22,229	Subtotal	
		Contractor Oversight	\$2,223		
		Total:	\$24,452		
Totals	\$0				
Summary of Existing Building-Related Heat Loads	Building Operating Load (kBtu/year)	Projected Fuel Usage Gallons	Fuel Cost	Peak Heating Load (kBtu/hr)	2 ASHP @ 110% of design Load
Space Heating Load	37,705	407	\$1,321	51	56
Thermostat Setback Savings		-84			
Cooling Load kWh	7,200		\$1,211		
			Total	\$2,531	
New Condition:					
Heating kWh	3,247		\$546		
Cooling Load kWh	4,824		\$811		
Electric Savings kWh	-871		New Total:	\$1,357	
			Savings:	\$1,174	
Simple Payback Calculation		Cost	Savings	Payback	
Full Cost Basis:		\$24,452	\$1,174	20.8	
Incremental Cost Difference:		\$24,452	\$1,174	20.8	

H2i™ LIGHT COMMERCIAL SOLUTIONS P-SERIES



It's below freezing outside? No sweat. The P-Series Hyper-Heating INVERTER systems work to provide the perfect temperature inside. It's all possible thanks to our responsive INVERTER compressor and patented flash injection technology. Even at 0° F, air-conditioning is possible with our wind baffle accessory. These light commercial zone solutions are perfect for any business, place of worship or school in any region of the country.


- 80% Hyper-Heating performance down to -13° F outdoor ambient.
- 100% heating capacity at 5° F outdoor ambient.
- PUZ-HA30NHA4: 18,000 - 30,000 Btu/h cooling / 18,000 - 34,000 Btu/h heating.
- PUZ-HA36NHA4: 18,000 - 34,200 Btu/h cooling / 18,000 - 40,000 Btu/h heating.
- Many ENERGY STAR tax credit qualifying systems.
- Low ambient cooling to 0° F with wind baffle.



P-Series (PUZ-HA) Features

Our exclusive H2i P-Series units recover heat energy that is normally wasted in the flash process at the outdoor coil. H2i flash technology helps the system overcome issues associated with conventional heat pumps, such as decreases in low-side pressure, refrigerant mass flow rate, and operational capacity. What you'll see is that the H2i P-Series units deliver 100% of rated heating capacity at 5° F and 80% at minus 13° F outdoor ambient temperatures (without the use of energy-consuming electric-resistance heaters).

- HOT START PROCESS**
means warm air flows from the start
- TWINNING OF TWO**
36,000 Btu/h outdoor units possible from one 36,000 Btu/h outdoor unit for wide distribution of capacity
- LINE LENGTHS**
up to 245 ft
- AUTOMATIC RESTART**
Peace of mind and ease of use in the event of power outage
- MULTIPLE FAN SPEEDS**
- AUTO COOLING/ HEATING CHANGEOVER**
- DRY MODE**



Ductwork is inefficient, costly and soon to be a thing of the past. The MSZ-FH family of Hyper-Heating INVERTER residential systems offer year-round, high-efficiency cooling and heating for bedrooms, basements, sunrooms and more. Essentially, heat pumps are now a realistic option for any home, in any climate.

M-Series (MSZ-FH) **NEW**

- Industry-leading efficiencies.
 - MSZ-FH09NA [30.5 SEER].
 - MSZ-FH12NA [26 SEER].
 - MSZ-FH15NA [21.5 SEER].
- Hyper-Heating performance down to -13° F outdoor ambient.
- 100% heating capacity at 5° F outdoor ambient.



BASELINE HEAT BALANCE CALCULATIONS

HEAT BALANCE				
GAINS AND LOSSES		BTU/HEATING SEASON* 1E6		
CONDUCTION LOSSES		-128.4		
INFILTRATION LOSSES		-29.6		
VENTILATION LOSSES		-9.6		
SOLAR GAIN		17.4		
OCCUPANT GAIN		1.9		
ELECTRICAL GAIN		72.0		
NET HEATING DEMAND		-76.2		
	Net Heating Demand (MMbtu)	/Energy Required (MMbtu)	Seasonal Efficiency %	
	76.2	114.1	67%	

Temperature & Schedule Information							
Building Name: Police Station							
Total Heating Days	212			Floor SF			
Outdoor, Winter Median Temperature	35			1,765			
	Wing name	Occupied Temp.	Unoccupied Temp.		Htg System Occ. Hrs per day *	Schedule	Occ Level Heating Days
			Night	Off days			
1	Office Side (Left 2/3rds)	70	70	70	24	7 days per week	212
2	Meeting/Locker Side (Right 1/3rd)	70	70	70	24	7 days per week	212

HEAT LOSS COEFFICIENTS						
Zone #	Building Zone		U-Value (BTU/hr-sf-F)	Area (sf)		UA-Value (BTU/hr-F)
1	Office Side (Left 2/3rds) <i>67% of the building</i>	Ceiling 1	0.053	1,198		63
						0
		Wall 1	0.127	991		126
						0
		Doors 1	0.580	47		27
		Doors2	0.160	11		2
		Windows 1	0.910	92		84
						0
		Floor	0.152	1,177		179
		Wing UA Total				480.7
2	Meeting/Locker Side (Right 1/3rd) <i>33% of the building</i>	Ceiling 1	0.053	598		32
						0
		Wall 1	0.127	495		63
						0
		Doors 1	0.580	23		14
		Doors2	0.160	6		1
		Windows 1	0.910	46		42
						0
		Floor	0.152	588		89
		Wing UA Total				240.0
Building Total UA:				720.8		

CONDUCTION LOSSES							
#	Zone	UA	HOURS/DAY	DAYS/ -	TEMP DIFF	LOSSES (* 1E6)	Sub Totals
1	Office Side (Left 2/3rds)	481	24	212	35	86	
		481	0	212	35	0	
		481	24	0	35	0	85.6
2	Meeting/Locker Side (Right 1/3rd)	240	24	212	35	43	
		240	0	212	35	0	
		240	24	0	35	0	42.7
Total UA		721	Conduction Total			128.4	

INFILTRATION LOSSES									
0.6									
#	Zone	VOLUME	ACH	HRS/ DAY	DAYS/ YR	0.018	TEMP DIFF	LOSSES (* 1E6)	Sub Totals
1	Office Side (Left 2/3rds)	10,251	0.60	0	212	0.018	35	0.0	
		10,251	0.60	24	0	0.018	35	0.0	
	Occ.	10,251	0.60	24	212	0.018	35	19.7	19.7
2	Meeting/Locker Side (Right 1/3rd)	5,118	0.60	0	212	0.018	35	0.0	
		5,118	0.60	24	0	0.018	35	0.0	
	Occ.	5,118	0.60	24	212	0.018	35	9.8	9.8
Infiltration Total									29.6

VENTILATION LOSSES								
Zone #	Area Name	CFM	1.08	HOURS/ DAY	DAYS/ -	TEMP DIFF	LOSSES (* 1E6)	
1	Office Side (Left 2/3rds)	25	1.08	24	212	35	4.8	
2	Meeting/Locker Side (Right 1/3rd)	25	1.08	24	212	35	4.8	
50							Ventilation Total	9.6

Enclosure ECM 1.1 Heat Balance

Enclosure ECM 1.1: HEAT BALANCE	
GAINS AND LOSSES	
BTU/HEATING SEASON*1E6	
CONDUCTION LOSSES	-94.8
INFILTRATION LOSSES	-24.6
VENTILATION LOSSES	-9.6
SOLAR GAIN	17.4
OCCUPANT GAIN	1.9
ELECTRICAL GAIN	72.0
NET HEATING DEMAND	-37.7

Enclosure ECM 1.1: HEAT LOSS COEFFICIENTS							
Zone #	Building Zone		U-Value (BTU/hr-sf-F)	Area (sf)		UA-Value (BTU/hr-F)	
1	Office Side (Left 2/3rds)	Ceiling 1	0.053	1,015		54	
		<i>56% of the building</i>					0
		Wall 1	0.127	840		106	
						0	
		Doors 1	0.580	40		23	
		Doors2	0.160	9		2	
		Windows 1	0.910	78		71	
						0	
		Improved Floor	0.045	997		45	
		Wing UA Total					300.7
2	Meeting/Locker Side (Right 1/3rd)	Ceiling 1	0.053	781		41	
		<i>44% of the building</i>					0
		Wall 1	0.127	647		82	
						0	
		Doors 1	0.580	30		18	
		Doors2	0.160	7		1	
		Windows 1	0.910	60		55	
						0	
		Improved Floor	0.045	768		35	
		Wing UA Total					231.6
Building Total UA:					532.3		

Enclosure ECM 1.1: CONDUCTION LOSSES							
#	Zone	UA	HOURS/ DAY	DAYS/ -	TEMP DIFF	LOSSES (* 1E6)	Sub Totals
1	Office Side (Left 2/3rds)	301	24	212	35	54	53.6
		301	0	212	35	0	
		301	24	0	35	0	
2	Meeting/Locker Side (Right 1/3rd)	232	24	212	35	41	41.2
		232	0	212	35	0	
		232	24	0	35	0	
Total UA		532	Conduction Total				94.8

Enclosure ECM 1.1: INFILTRATION LOSSES									
0.5									
#	Zone	VOLUME	ACH	HRS/ DAY	DAYS/ YR	0.018	TEMP DIFF	LOSSES (* 1E6)	Sub Totals
1	Office Side (Left 2/3rds)	8,682	0.50	0	212	0.018	35	0.0	13.9
		8,682	0.50	24	0	0.018	35	0.0	
		Occ.	8,682	0.50	24	212	0.018	35	
2	Meeting/Locker Side (Right 1/3rd)	6,687	0.50	0	212	0.018	35	0.0	10.7
		6,687	0.50	24	0	0.018	35	0.0	
		Occ.	6,687	0.50	24	212	0.018	35	
Infiltration Total									24.6

Enclosure ECM 1.2 Heat Balance

Revised Enclosure ECM 1.2: HEAT BALANCE	
GAINS AND LOSSES	
BTU/HEATING SEASON* 1E6	
CONDUCTION LOSSES	-97.3
INFILTRATION LOSSES	-24.6
VENTILATION LOSSES	-9.6
SOLAR GAIN	17.4
OCCUPANT GAIN	1.9
ELECTRICAL GAIN	72.0
NET HEATING DEMAND	-40.2

Revised Enclosure ECM 1.2: HEAT LOSS COEFFICIENTS							
Zone #	Building Zone		U-Value (BTU/hr-sf-F)	Area (sf)		UA-Value (BTU/hr-F)	
1	Office Side (Left 2/3rds) <i>56% of the building</i>	Ceiling 1	0.053	1,015		54	
						0	
	Wall 1	0.127	840	106			
	Doors 1	0.580	40	23			
	Doors 2	0.160	9	2			
	Windows 1	0.910	78	71			
	Crawlspace 'Walls'	0.036	214	8			
	Crawlspace 'Floor'	0.410	107	44			
	Improved Floor			removed		0	
	Wing UA Total					307.1	
	2	Meeting/Locker Side (Right 1/3rd) <i>44% of the building</i>	Ceiling 1	0.053		781	41
							0
		Wall 1	0.127	647		82	
Doors 1		0.580	30	18			
Doors 2		0.160	7	1			
Windows 1		0.910	60	55			
Crawlspace 'Walls'		0.036	176	6			
Crawlspace 'Floor'		0.410	88	36			
Improved Floor				removed	0		
Wing UA Total				239.2			
Building Total UA:					546.3		

Revised Enclosure ECM 1.2: CONDUCTION LOSSES								
#	Zone	UA	HOURS/ DAY	DAYS/ -	TEMP DIFF	LOSSES (* 1E6)	Sub Totals	
1	Office Side (Left 2/3rds)	307	24	212	35	55		
		307	0	212	35	0		
		307	24	0	35	0		54.7
2	Meeting/Locker Side (Right 1/3rd)	239	24	212	35	43		
		239	0	212	35	0		
		239	24	0	35	0		42.6
Total UA		546	Conduction Total				97.3	

Revised Enclosure ECM 1.2: INFILTRATION LOSSES									
0.5									
#	Zone	VOLUME	ACH	HRS/ DAY	DAYS/ YR	0.018	TEMP DIFF	LOSSES (* 1E6)	Sub Totals
1	Office Side (Left 2/3rds)	8,682	0.50	0	212	0.018	35	0.0	
		8,682	0.50	24	0	0.018	35	0.0	
		Occ.	8,682	0.50	24	212	0.018	35	
2	Meeting/Locker Side (Right 1/3rd)	6,687	0.50	0	212	0.018	35	0.0	
		6,687	0.50	24	0	0.018	35	0.0	
		Occ.	6,687	0.50	24	212	0.018	35	
Infiltration Total									24.6

Zoning & Control ECM 2.1 Heat Balance

Zoning & Control ECM 2.1: HEAT BALANCE	
GAINS AND LOSSES	
BTU/HEATING SEASON*1E6	
CONDUCTION LOSSES	-88.6
INFILTRATION LOSSES	-23.0
VENTILATION LOSSES	-9.6
SOLAR GAIN	17.4
OCCUPANT GAIN	1.9
ELECTRICAL GAIN	72.0
NET HEATING DEMAND	-29.9

Zoning & Control ECM 2.1:		Temperature & Schedule Information					
		Building Name: Police Station					
Total Heating Days	212				Floor SF		
Outdoor, Winter Median Temperature	35				1,765		
	Wing name	Occupied Temp.	Unoccupied Temp.		Htg System Occ. Hrs per day *	Schedule	Occ Level Heating Days
			Night	Off days			
1	Office Side (Left 2/3rds)	70	70	70	24	7 days per week	212
2	Meeting/Locker Side (Right 1/3rd)	70	65	60	8	7 days per week	151

Zoning & Control ECM 2.1: CONDUCTION LOSSES								
#	Zone	UA	HOURS/ DAY	DAYS/ -	TEMP DIFF	LOSSES (* 1E6)	Sub Totals	
1	Office Side (Left 2/3rds)	301	24	212	35	54		
		301	0	212	35	0		
		301	24	0	35	0		53.6
2	Meeting/Locker Side (Right 1/3rd)	232	8	151	35	10		
		232	16	151	30	17		
		232	24	61	25	8		35.1
Total UA		532	Conduction Total				88.6	

Zoning & Control ECM 2.1: INFILTRATION LOSSES									
0.5									
#	Zone	VOLUME	ACH	HRS/ DAY	DAYS/ YR	0.018	TEMP DIFF	LOSSES (* 1E6)	Sub Totals
1	Office Side (Left 2/3rds)	8,682	0.50	0	212	0.018	35	0.0	
		8,682	0.50	24	0	0.018	35	0.0	
		Occ.	8,682	0.50	24	212	0.018	35	
2	Meeting/Locker Side (Right 1/3rd)	6,687	0.50	16	151	0.018	30	4.4	
		6,687	0.50	24	61	0.018	25	2.2	
		Occ.	6,687	0.50	8	151	0.018	35	
Infiltration Total									23.0

GREENHOUSE GAS EMISSIONS

Greenhouse Gas (GHG) Impact								
Baseline Fuel Usage		Natural Gas	Propane	Oil	Electricity	MT eCO ₂		
Space Heating & Domestic Hot Water				823		8.5		
Measure #	Measure Description <i>(RTM = Renewable Thermal Measure)</i> <i>(ECM = Energy Conservation Measure)</i>	Fuel Usage After Measures				GHG Emissions (MT eCO ₂)	GHG Savings (MT eCO ₂)	Savings As % of Baseline
		Natural Gas (MMBtu / yr)	Propane (gal / yr)	Oil (gal / yr)	Electricity (kWh / yr)			
ECM 1.1	Insulate & Air Seal the Floor			407		4.2	4.3	51%
OR								
ECM 1.2	Construct Insulated & Sealed Crawlspace			434		4.5	4.0	47%
ECM 2.1	Energy Management System Controls			323		3.3	0.9	10%
OR								
ECM 2.2	Heating with Air Source Heat Pump (ASHP)				3,247	1.1	3.1	37%

GHG Emissions		
10.3	MT eCO ₂ / 1,000	gallons of #2 Fuel Oil
5.3	MT eCO ₂ / 1,000	gallons of Propane (LPG)
53.2	MT eCO ₂ / 1,000	MMBtu's of Natural Gas
14.1	MT eCO ₂ / 100	short ton of wood pellets (2,000 lbs.)
333.7	MT eCO ₂ / 1,000,000	kWh of electricity
<i>per Clean Air Cool Planet Campus Carbon Calculator (2013 value)</i>		